City of St. Charles Swimming Pools (Above ground & In-ground) and Spas



Building Zoning Division 2 East Main Street St. Charles IL 60174 630.377.4406 (Office) 630.443.4638 (Fax) http://www.stcharlesil.gov

Please direct any and all questions to the City of St. Charles Building Zoning Division: Monday (8 AM to 7 PM) Tuesday through Friday (8 AM to 4:30 PM) at 630.377.4406

This is a summary of the City of St. Charles ordinances affecting Pool and Spa Construction. A building permit is required prior to any construction of a swimming pool (Above ground or in-ground) and spas that contain water over 24-inches. The following are guidelines and comments for obtaining a building permit.

Application and Drawings Procedures:

- ► An application is to be filled out and submitted to the Building Department. The contractors names, addresses, phone numbers and, if required, their license numbers are to be filled out when submitting the application.
- ► Two (2) sets of drawings showing the construction details for the pool or spa are to be submitted with the application. Include in these plans:
 - * Catalog specification sheet (NSF approval required)
 - * Anti-Vortex main drain
 - * Skimmer wells, pump, filter, lights, and heaters
 - * Diving board slides
 - * Any other applicable equipment
 - * Electric plan (please see attachment)
- ► Two (2) copies of the plat of survey showing the measurements to lot lines drawn on the survey and indicate the location of:
 - ***** Pool − Spa
 - * Path of electric service to the house (see clearances)
 - * No pool or spa may be placed closer than five (5') feet to the lot line, or be located in an easement.
- ▶ Our goal is to complete the review for your building permit within 10 working days.

Application – Permit Fees:

- ⇒ A filing fee is to be paid at time of submission of application and drawings or plans.
 - In-ground Pool \$160.00 - Above Ground Pool - \$45.00
- ⇒ **Re-inspection fee**. During the construction of your project should you fail any of the required inspections there is a re-inspection charge. The fees are due prior to certificate of occupancy. The fee schedule is as follows:
 - \$60.00 per Building Department re-inspection for all types of inspections during construction (excluding finals)
 - \$80.00 per re-inspection for all residential final inspections.

Application – Permit Fees Continued:

⇒ **Temporary certificate of occupancies**. \$80.00 is due prior to issuance of a temporary certificate of occupancy for residential.

Barrier or Fencing:

- Barrier placement pool excavation must be protected during construction with approved fencing.
- Permanent barrier or fencing must be in place prior to filling.
- ☼ Silt fence required during construction.
- A barrier or fence is to be constructed per the 2000 International Residential Code. A copy of the section of the code is attached for your information.
- ☼ If a fence is installed, a Fence Affidavit is to be completed and submitted with the application.
 - The Affidavit is to be completed in black ink
 - The Affidavit is to be notarized

Inspections:

The following is a list of inspections, which might be required for your project.

- Air test
- Underground Electric
- o Plumbing
- o Gas
- o Concrete Bonding
- o Fence
- o Final

Building Codes:

The following are the Building Codes, which the City of St. Charles has adopted:

- o St. Charles Municipal Code
- o 2003 Int'l Building Code w/revisions
- o 2003 Int'l Mechanical Code w/revisions
- o 2002 Nat'l Electrical Code w/revisions
- o 1998 IL State Plbg Code w/revisions
- o 2000 Int'l Residential Code/revisions
- o Fire Prevention Codes
- O 2003 Int'l Fuel Gas Code w/revisions

Homeowner – Contractor Responsibilities:

- ✓ It is the responsibility of the homeowner/contractor to schedule with the Building Department the required inspections. The required inspections are indicated on the Plan Review form, which is attached to your permit and the Field Copy of drawings. When calling to schedule an inspection, please have the <u>address and the permit number.</u>
- ✓ Inspections shall be called a minimum of 24 hours before they become due.
- ✓ Call J.U.I.L.E. (Joint Underground Location for Inspectors and Engineers) at least 48-hours prior to any digging to locate any underground utilities. (1-800/892-0123)


•	Electric Utilities	Red
•	Comcast (Cable)	Orange
•	Northern Illinois Gas (NICOR)	Yellow
•	Sewer Utilities	Green
•	Telephone Utilities	Orange
•	Water Utilities	Blue

Electric Requirements:

- → The electric requirements are based upon the 2002 National Electric Code.
- → Section 680.0 Overhead clearances:
- → 22-feet 6-inches above water edge
- → 14-feet 0-Inches above any platform with in the pool and 10-feet each side of the pool

Electric Requirements, continued

- → Section 680.10 Underground Clearance:
- → 5-feet horizontal from the inside of the pool wall or meet exceptions
- → All boxes, covers, and fittings are to be weatherproof outdoor type and sunlight resistant.
- → Section 680.10 Minimum burial depth of electric to pool as follows rigid metal conduit 6-inches, intermediate metal conduit 6-inches, nonmetallic PVC 18-inches, and should be listed for electric (gray in color) direct burial cable 24-inches with rigid sleeve from elbow up.
- → All motors shall be listed and labeled per 110-3(B) UL or equivalent by an approved testing agency to the U.S. standards.
- → Section 680.21 (B) For all non-double insulated pump motors, a bond is required to the motor housing, the pool frame, and all metal conduits.
- → Section 680.22(A)(1) 5-feet minimum 10-feet maximum to receptacle that provides power to pool equipment and consist of single receptacle, locking configuration (twist lock), grounding type, and GFCI protection.
- → Section 680.26 (4) #8 Solid copper wire to bond all metal parts 5-feet horizontally away from inside of pool wall (plastic pool with metal top ring requires bonding) by pressure connectors or clamps labeled as being suitable for the purpose. (See section)
- → Section 680.22(2)(3) General purpose receptacle required 10-feet 20-feet from the inside wall of the pool, may be on house GFI.
- → Section 680.12 Maintenance disconnect (switch) required to be accessible and within sight of its equipment.
- → Section 680.21(5) Cord and plug connection on motors shall not exceed 3-feet in length.
- → Section 680.7 Grounding of all electric equipment per 250.122 not to be smaller than 12 AWG to include wall lighting and underwater luminaries, electric equipment within 5-feet of inside wall of pool, electric equipment associated with recirculating system, junction boxes, transformer enclosures, ground fault circuit interrupters, panel boards that are not part of the service equipment and that supply any electrical equipment associated with the pool.



APPENDIX G

SWIMMING POOLS, SPAS AND HOT TUBS

SECTION AG101 GENERAL

AG101.1 General. The provisions of this appendix shall control the design and construction of swimming pools, spas and hot tubs installed in or on the lot of a one- and two-family dwelling.

SECTION AG102 DEFINITIONS

AG102.1 General. For the purposes of these requirements, the terms used shall be defined as follows and as set forth in Chapter 2.

ABOVE-GROUND/ON-GROUND POOL. See "Swimming pool."

BARRIER. A fence, wall, building wall or combination thereof which completely surrounds the swimming pool and obstructs access to the swimming pool.

HOT TUB. See "Swimming pool."

IN-GROUND POOL. See "Swimming pool."

RESIDENTIAL. That which is situated on the premises of a detached one- or two-family dwelling or a one-family townhouse not more than three stories in height.

SPA, NONPORTABLE. See "Swimming pool."

SPA, PORTABLE. A nonpermanent structure intended for recreational bathing, in which all controls, water-heating and water-circulating equipment are an integral part of the product.

SWIMMING POOL. Any structure intended for swimming or recreational bathing that contains water over 24 inches (610 mm) deep. This includes in-ground, aboveground and on-ground swimming pools, hot tubs and spas.

SWIMMING POOL, INDOOR. A swimming pool which is totally contained within a structure and surrounded on all four sides by walls of said structure.

SWIMMING POOL, OUTDOOR. Any swimming pool which is not an indoor pool.

SECTION AG103 SWIMMING POOLS

AG103.1 In-ground pools. In-ground pools shall be designed and constructed in conformance with ANSI/NSPI-5 as listed in Section AG107.

AG103.2 Above-ground and on-ground pools. Above-ground and on-ground pools shall be designed and constructed in conformance with ANSI/NSPI-4 as listed in Section AG107.

SECTION AG104 SPAS AND HOT TUBS

AG104.1 Permanently installed spas and hot tubs. Permanently installed spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-3 as listed in Section AG107.

AG104.2 Portable spas and hot tubs. Portable spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-6 as listed in Section AG107.

SECTION AG105 BARRIER REQUIREMENTS

AG105.1 Application. The provisions of this chapter shall control the design of barriers for residential swimming pools, spas and hot tubs. These design controls are intended to provide protection against potential drownings and mar-drownings by restricting access to swimming pools, spas and hot tubs.

AG105.2 Outdoor swimming pool. An outdoor swimming pool, including an in-ground, aboveground or on-ground pool, hot tub or spa shall be provided with a barrier which shall comply with the following:

- 1. The top of the barrier shall be at least 48 inches (1219 mm) above grade measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 2 inches (51 mm) measured on the side of the barrier which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an aboveground pool, the barrier may be at ground level, such as the pool structure, or mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier shall be 4 inches (102 mm).
- 2. Openings in the barrier shall not allow passage of a 4-inch-diameter (102 mm) sphere.
- Solid barriers which do not have openings, such as a masonry or stone wall, shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.
- 4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall not exceed 1.75 inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1.75 inches (44 mm) in width.
- 5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches (1143 mm) or more, spacing

- between vertical members shall not exceed 4 inches (102 mm). Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1.75 inches (44 mm) in width.
- 6. Maximum mesh size for chain link fences shall be a 1.25-inch (32 mm) square unless the fence is provided with slats fastened at the top or the bottom which reduce the openings to not more than 1.75 inches (44 mm).
- Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members shall not be more than 1.75 inches (44 mm).
- 8. Access gates shall comply with the requirements of Section AG105.2, Items 1 through 7, and shall be equipped to accommodate a locking device. Pedestrian access gates shall open outward away from the pool and shall be self-closing and have a self-latching device. Gates other than pedestrian access gates shall have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches (1372 mm) from the bottom of the gate, the release mechanism and openings shall comply with the following:
 - 8.1. The release mechanism shall be located on the pool side of the gate at least 3 inches (76 mm) below the top of the gate, and
 - 8.2. The gate and barrier shall have no opening greater than 0.5 inch (12.7 mm) within 18 inches (457 mm) of the release mechanism.
- 9. Where a wall of a dwelling serves as part of the barrier one of the following conditions shall be met:
 - 9.1. The pool shall be equipped with a powered safety cover in compliance with ASTM F1346; or
 - 9.2. All doors with direct access to the pool through that wall shall be equipped with an alarm which produces an audible warning when the door and its screen, if present, are opened. The alarm shall sound continuously for a minimum of 30 seconds immediately after the door is opened and be capable of being heard throughout the house during normal household activities. The alarm shall automatically reset under all conditions. The alarm system shall be equipped with a manual means, such as touchpad or switch, to temporarily deactivate the alarm for a single opening. Such deactivation shall last for not more than 15 seconds. The deactivation switch(es) shall be located at least 54 inches (1372 mm) above the threshold of the door; or
 - 9.3. Other means of protection, such as self-closing doors with self-latching devices, which are approved by the governing body, shall be acceptable so long as the degree of protection afforded is not less than the protection afforded by Item 9.1 or 9.2 described above.
- 10. Where an aboveground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps, then:
 - 10.1. The ladder or steps shall be capable of being secured, locked or removed to prevent access, or

10.2. The ladder or steps shall be surrounded by a barrier which meets the requirements of Section AG105.2, Items 1 through 9. When the ladder or steps are secured, locked or removed, any opening created shall not allow the passage of a 4-inch-diameter (102 mm) sphere.

AG105.3 Indoor swimming pool. All walls surrounding an indoor swimming pool shall comply with Section AG105.2, Item 9.

AG105.4 Prohibited locations. Barriers shall be located so as to prohibit permanent structures, equipment or similar objects from being used to climb the barriers.

AG105.5 Barrier exceptions. Spas or hot tubs with a safety cover which complies with ASTM F 1346, as listed in Section AG107, shall be exempt from the provisions of this appendix.

SECTION AG106 ABBREVIATIONS

AG106.1 General.

ANSI—American National Standards Institute 11 West 42nd Street, New York, NY 10036

ASTM—American Society for Testing and Materials 1916 Race Street, Philadelphia, PA 19103

NSPI—National Spa and Pool Institute 2111 Eisenhower Avenue, Alexandria, VA 22314


SECTION AG107 STANDARDS

AG107.1 General.

ANSI/NSPI

ANSI/NSPI-3 Standard for Permanently Installed Residential Spas
ANSI/NSPI-4 Standard for Above-ground/On-ground Residential Swimming Pools
ANSI/NSPI-5 Standard for Residential In-ground Swimming Pools
ANSI/NSPI-6 Standard for Residential Portable Spas
ASTM

SAFETY BARRIER GUIDELINES FOR HOME POOLS




wimming pools should always be happy places.
Unfortunately, each year thousands of American families confront swimming pool tragedies—drownings and near-drownings of young children.
These tragedies are preventable. This U.S. Consumer Product Safety Commission (CPSC) handbook offers guidelines for pool barriers that can help prevent most submersion incidents involving young children.

This handbook is designed for use by owners, purchasers, and builders of residential pools, spas, and hot tubs.

The swimming pool barrier guidelines are not a CPSC standard and are not mandatory requirements. Therefore, the Commission does not endorse these guidelines as the sole method to minimize pool drownings of young children. The Commission believes, however, that the safety features recommended in this handbook will help make pools safer. Publication of this handbook is expected to promote pool safety awareness among owners, purchasers and builders of swimming pools.

Some localities have incorporated the guidelines in this handbook into their building codes. Check with your local authorities to see whether these guidelines are included in your area's building code or in other regulations.



Why the Swimming Pool Guidelines Were Developed

ach year, hundreds of young children die and thousands come close to death due to submersion in residential swimming pools. CPSC has estimated that each year about 300 children under 5 years old drown in swimming pools. The Commission estimates hospital emergency room treatment is required for more than 2,000 children under 5 years of age who were submerged in residential pools.

CPSC did an extensive study of swimming pool accidents, both fatal drownings and near-fatal submersions, in California, Arizona and Florida, states in which home swimming pools are very popular and in use during much of the year. The findings from that study led Commission staff to develop the guidelines in this handbook.

- In California, Arizona and Florida, drowning was the leading cause of accidental death in and around the home for children under the age of 5 years.
- 75 percent of the children involved in swimming pool submersion or drowning accidents were between 1 and 3 years old.
- Boys between 1 and 3 years old were the most likely victims of fatal drownings and near-fatal submersions in residential swimming pools.

- Most of the victims were being supervised by one or both parents when the swimming pool accident occurred.
- Nearly half of the child victims were last seen in the house before the pool accident occurred. In addition, 23 percent of the accident victims were last seen on the porch or patio, or in the yard.
- This means that fully 69 percent of the children who became victims in swimming pool accidents were not expected to be in or at the pool, but were found drowned or submerged in the water.
- 65 percent of the accidents occurred in a pool owned by the victim's immediate family, and 33 percent of the accidents occurred in pools owned by relatives or friends.
- Fewer than 2 percent of the pool accidents were a result of children trespassing on property where they didn't live or belong.
- 77 percent of the swimming pool accident victims had been missing for five minutes or less when they were found in the pool drowned or submerged.

The speed with which swimming pool drownings and submersions can occur is a special concern: by the time a child's absence is noted, the child may have drowned. Anyone who has cared for a toddler knows how fast young children can move. Toddlers are inquisitive and impulsive and lack a realistic sense of danger. These behaviors, coupled with a child's ability to move quickly and unpredictably make swimming pools particularly hazardous for households with young children.

Swimming pool drownings of young children have another particularly insidious feature: these are silent deaths. It is unlikely that splashing or screaming will occur to alert a parent or caregiver that a child is in trouble.

CPSC staff have reviewed a great deal of data on drownings and child behavior, as well as information on pool and pool barrier construction. The staff concluded that the best way to reduce child drownings in residential pools was for pool owners to construct and maintain barriers that would prevent young children from gaining access to pools. However, there are no substitutes for diligent supervision.

The Swimming Pool Barrier Guidelines

How to Prevent a Child from Getting OVER a Pool Barrier


his section explains the CPSC swimming pool barrier guidelines with illustrated descriptions of pool barriers. Definitions of terms used in the guidelines are provided on page 6.

The definition of pool includes spas and hot tubs; the swimming pool barrier guidelines therefore apply to these structures as well as to conventional swimming pools.


> A successful pool barrier prevents a child from getting OVER, UNDER, or THROUGH and keeps the child from gaining access to the pool except when supervising adults are present.

young child can get over a pool barrier if the barrier is too low or if the barrier has handholds or footholds for a child to use when climbing.

The guidelines recommend that the top of a pool barrier be at least 48 inches above grade, measured on the side of the barrier which faces away from the swimming pool.



Guidelines recommend eliminating handholds and footholds and minimizing the size of openings in a barrier's construction. For a Solid Barrier: No indentations or protrusions should be present, other than normal construction tolerances and masonry joints.




For a Barrier (Fence) Made Up of Horizontal and


Vertical Members: If the distance between the tops of the horizontal members is less than 45 inches, the horizontal members should be on the swimming pool side of the fence. The spacing of the vertical members should not exceed 1-3/4 inches. This size

young child and is intended to reduce the potential for a child to gain a foothold. If there are any decorative cutouts in the fence, the space within the cutouts should not exceed 1-3/4 inches.

is based on the foot width of a





If the distance between the tops of the horizontal members is more than 45 inches, the horizontal members can be on the side of the fence facing away from the pool. The spacing between vertical members should not exceed 4 inches. This size is based on the head breadth and chest depth of a young child and is intended to prevent a child from passing through an opening. Again, if there are any decorative cutouts in the fence, the space within the cutouts should not exceed 1-3/4 inches.



For a Chain Link Fence:


The mesh size should not exceed 1-1/4 inches square unless slats, fastened at the top or bottom of the fence, are used to reduce mesh openings to no more than 1-3/4 inches.






For a Fence Made Up of Diagonal Members (Latticework):

The maximum opening in the lattice should not exceed 1-3/4 inches.




For Aboveground Pools:



Aboveground pools should have barriers. The pool structure itself serves as a barrier or a barrier is mounted on top of the pool structure.


Then, there are two possible ways to prevent young children from climbing up into an aboveground pool. The steps or ladder can be designed to be secured, locked or removed to prevent access, or the steps or ladder can be surrounded by a barrier such as those described above.



How to Prevent a Child from Getting UNDER a Pool Barrier


How to Prevent a Child from Getting THROUGH a Pool Barrier

or any pool barrier, the maximum clearance at the bottom of the barrier should not exceed 4 inches above grade, when the measurement is done on the side of the barrier facing away from the pool.



Aboveground Pool with Barrier on Top of Pool:

If an aboveground pool has a barrier on the top of the pool, the maximum vertical clearance between the top of the pool and the bottom of the barrier should not exceed 4 inches.



Preventing a child from getting through a pool barrier can be done by restricting the sizes of openings in a barrier and by using self-closing and self-latching gates.

To prevent a young child from getting through a fence or other barrier, all openings should be small enough so that a 4-inch diameter sphere cannot pass through. This size is based on the head breadth and chest depth of a young child.



Gates:


There are two kinds of gates which might be found on a residential property. Both can play a part in the design of a swimming pool barrier.

Pedestrian Gates:

These are the gates people walk through. Swimming pool barriers should be equipped with a gate or gates which restrict access to the pool. A locking device should be included in the gate design. Gates should open out from the pool and should be selfclosing and self-latching. If a gate is properly designed, even if the gate is not completely latched, a young child pushing on the gate in order to enter the pool area will at least close the gate and may actually engage the latch.



When the release mechanism of the self-latching device is less than 54 inches from the bottom of the gate, the release mechanism for the gate should be at least 3 inches below the top of the gate on the side facing the pool. Placing the release mechanism at this height prevents a young child from reaching over the top of a gate and releasing the latch.



Also, the gate and barrier should have no opening greater than 1/2 inch within 18 inches of the latch release mechanism. This prevents a young child from reaching through the gate and releasing the latch.

All Other Gates (Vehicle Entrances, Etc.):

Other gates should be equipped with self-latching devices. The self-latching devices should be installed as described for pedestrian gates.

When the House Wall Forms Part of the Pool Barrier:

In many homes, doors open directly onto the pool area or onto a patio which leads to the pool.



In such cases, the wall of the house is an important part of the pool barrier, and passage through any doors in the house wall should be controlled by security measures. The importance of controlling a young child's movement from house to pool is demonstrated by the statistics obtained during CPSC's study of pool incidents in California, Arizona and Florida: almost half (46 percent) of the children who became victims of pool accidents were last seen in the house just before they were found in the pool.

All doors which give access to a swimming pool should be equipped with an audible alarm which sounds when the door and/or screen are opened. The alarm should sound for 30 seconds or more within 7 seconds after the door is opened. Alarms should

meet the requirements of UL 2017 General-Purpose Signaling Devices and Systems, Section 77.

The alarm should be loud: at least 85 dBA (decibels) when measured 10 feet away from the alarm mechanism. The alarm sound should be distinct from other sounds in the house, such as the telephone, doorbell and smoke alarm. The alarm should have an automatic reset feature.

Because adults will want to pass through house doors in the pool barrier without setting off the alarm, the alarm should have a switch that allows adults to temporarily deactivate the alarm for up to 15 seconds. The deactivation switch could be a touchpad (keypad) or a manual switch, and should be located at least 54 inches above the threshold of the door covered by the alarm. This beight was selected based on the reaching ability of young children.


Power safety covers can be installed on pools to serve as security barriers. Power safety covers should conform to the specifications in ASTM F 1346-91. This standard specifies safety performance requirements for pool covers to protect young children from drowning.

If you wish further information on this standard, contact ASTM, Inc., Philadelphia, Pa. (formerly the American Society for Testing & Materials), directly.

Self-closing doors with self-latching devices could also be used to safeguard doors which give ready access to a swimming pool.

Indoor Pools:

When a pool is located completely within a house, the walls that surround the pool should be equipped to serve as pool safety barriers. Measures recommended above where a house wall serves as part of a safety barrier also apply for all the walls surrounding an indoor pool.



Barriers for Residential Swimming Pool, Spas, and Hot Tubs

The preceding explanations of the U.S. Consumer Product Safety Commission's pool barrier guidelines were provided in order to make it easier for pool owners, purchasers, builders, technicians and others to understand and apply the guidelines themselves. Detailed guidelines follow. Reading the following guidelines in conjunction with the diagrams previously provided may be especially helpful. For further information, consult your local building department or code authority.

Application

The guidelines presented in this document are intended to provide a means of protection against potential drownings and near-drownings to children under 5 years of age by restricting access to residential swimming poots, spas, and hot tubs.

Definitions

Aboveground/onground pool. See definition of swimming pool.

Barrier. A fence, a wall, a building wall or a combination thereof which completely surrounds the swimming pool and obstructs access to the swimming pool.

Hot tub. See definition of swimming pool.

Inground pool. See definition of swimming pool.

Residential. That which is situated on the premises of a detached one- or two-family dwelling or a one-family townhouse not more than three stories in height.

Spa, nonportable. See definition of swimming pool.

Spa, portable. A non-permanent structure intended for recreational bathing, in which all controls, water- heating, and water-circulating equipment are an integral part of the product and which is cord-connected (not permanently electrically wired).

Swimming pool. Any structure intended for swimming or recreational bathing that contains water over 24 inches deep. This includes inground, aboveground, and onground swimming pools, hot tubs, and spas.

Swimming pool, indoor. A swimming pool which is totally contained within a structure and surrounded on all four sides by walls of said structure.

Swimming pool, outdoor. Any swimming pool which is not an indoor pool.

Guidelines

Section I. Outdoor Swimming Pool

An outdoor swimming pool, including an inground, aboveground, or onground pool, hot tub, or spa, should be provided with a barrier which complies with the following:

- 1. The top of the barrier should be at least 48 inches above grade measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier should be 4 inches measured on the side of the barrier which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an aboveground pool, the barrier may be at ground level, such as the pool structure, or mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier should be 4 inches.
- 2. Openings in the barrier should not allow passage of a 4-inch diameter sphere.
- 3. Solid barriers, which do not have openings, such as a masonry or stone wall, should not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.

- 4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches, the horizontal members should be located on the swimming pool side of the fence. Spacing between vertical members should not exceed 1-3/4 inches in width. Where there are decorative cutouts, spacing within the cutouts should not exceed 1-3/4 inches in width.
- 5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches or more, spacing between vertical members should not exceed 4 inches. Where there are decorative cutouts, spacing within the cutouts should not exceed 1-3/4 inches in width.
- 6. Maximum mesh size for chain link fences should not exceed 1-3/4 inch square unless the fence is provided with slats fastened at the top or the bottom which reduce the openings to no more than 1-3/4 inches.
- 7. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members should be no more than 1-3/4 inches.
- 8. Access gates to the pool should comply with Section I, Paragraphs 1 through 7, and should be equipped to accommodate a locking device. Pedestrian access gates should open outward, away from the pool, and should be self-closing and have a self-latching device. Gates other than pedestrian access gates should have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches from the bottom of the gate, (a) the release mechanism should be located on the pool side of the gate at least 3 inches below the top of the gate

- and (b) the gate and barrier should have no opening greater than 1/2 inch within 18 inches of the release mechanism.
- 9. Where a wall of a dwelling serves as part of the barrier, one of the following should apply:
- (a) All doors with direct access to the pool through that wall should be equipped with an alarm which produces an audible warning when the door and its screen, if present, are opened. The alarm should sound continuously for a minimum of 30 seconds within 7 seconds after the door is opened. Alarms should meet the requirements of UL 2017 General-Purpose Signaling Devices and Systems, Section 77. The alarm should have a minimum sound pressure rating of 85 dBA at 10 feet and the sound of the alarm should be distinctive from other household sounds, such as smoke alarms, telephones, and door bells. The alarm should automatically reset under all conditions. The alarm should be equipped with manual means, such as touchpads or switches, to temporarily deactivate the alarm for a single opening of the door from either direction. Such deactivation should last for no more than 15 seconds. The deactivation touchpads or switches should be located at least 54 inches above the threshold of the door.
- **(b)** The pool should be equipped with a power safety cover which complies with ASTM F1346-91 listed below.
- (c) Other means of protection, such as self-closing doors with self-latching devices, are acceptable so long as the degree of protection afforded is not less than the protection afforded by (a) or (b) described above.
- 10. Where an aboveground pool structure is used as a barrier or where the barrier is

mounted on top of the pool structure, and the means of access is a ladder or steps, then (a) the ladder to the pool or steps should be capable of being secured, locked or removed to prevent access, or (b) the ladder or steps should be surrounded by a barrier which meets Section I, Paragraphs 1 through 9. When the ladder or steps are secured, locked, or removed, any opening created should not allow the passage of a 4-inch diameter sphere.

Section II. Indoor Swimming Pool.

All walls surrounding an indoor swimming pool should comply with Section I, Paragraph 9.

Section III. Barrier Locations.

Barriers should be located so as to prohibit permanent structures, equipment or similar objects from being used to climb the barriers.

Exemptions

A portable spa with a safety cover which complies with ASTM F1346-91 listed below should be exempt from the guidelines presented in this document. But, swimming pools, hot tubs, and non-portable spas with safety covers should not be exempt from the provisions of this document.

ASTM F1346-91. Standard Performance Specification for Safety Covers and Labeling Requirements for All Covers for Swimming Pools, Spas and Hot Tubs. For further information, write:
U.S. Consumer Product Safety Commission
Washington, D.C. 20207
Web site: www.cpsc.gov

To report a product hazard or a product-related injury, write to the U.S. Consumer Product Safety Commission, Washington, D.C. 20207, or call the CPSC's toll-free hotline at 1-800-638-2772 or visit its website at http://www.cpsc.gov.

A teletypewriter for the hearing and speaking impaired is available on: 1-800-638-8270.

This document is in the public domain. Therefore it may be reproduced, in part or in whole, without permission by an individual or organization. However, if it is reproduced, the Commission would appreciate knowing how it is used.

Write the U.S. Consumer Product Safety Commission, Office of Information and Public Affairs, Washington, D.C. 20207.

DO NOT WRITE OR MARK ABOVE THE LINE **Use Black Ink Only! Release and Indemnity Agreement** For Fences Located in Utility and Drainage Easements in the City of St. Charles

Name of Record Owner (s):_____

Fence Building Permit No.:

Address of Property:

Legal Description: (as shown on the plat of survey)

Use Black Ink Only!

Release and Indemnity Agreement For Fences Located in utility and Drainage Easements in the City of St. Charles

I (We), the undersigned, certify that I (we) am (are) the owner(s) of record of the real estate described herein, that I (we) have read Section 17.02.160 of the St. Charles Municipal Code and agree to comply with its requirements regarding fences located in utility or drainage easement areas. I (We) hereby release and agree to hold harmless the City of St. Charles, its officers, agents and employees from any liability or loss, including reasonable attorneys' fees, arising out of or in connection with the moving or removal of any fence or any other structure of form of landscaping within the easement area. I (We) further agree that the City of St. Charles, its officers, agents, and employees shall not be required to replace any such fence, structure of landscaping. This release and indemnity agreement shall be binding upon and inure to the benefit of my (our) heirs, successors, and assigns. Signature(s) of Owners Address Date This instrument prepared by: Robert J. Vann, Building and Zoning Commissioner City of St. Charles, 2 East Main Street, St. Charles, IL 60174-1984 **Affidavit** State of Illinois)) SS County of Kane) I, the undersigned, a Notary Public, in and for said County and State, DO HEREBY CERTIFY personally known to me to be the same person(s) whose name(s) subscribed to the foregoing instrument, appeared before me this day in person and acknowledged that signed, sealed and delivered the said instrument as free and voluntary act, for the uses and purposes therein set forth. Given under my hand notarial seal this _____day of _____, Notary Public

My Commission Expires:



CITY OF ST. CHARLES TWO EAST MAIN STREET ST. CHARLES, ILLINOIS 60174-1984

DEPARTMENT: BUILDING & ZONING PHONE: (630) 377-4406 FAX (630) 443-4638

APPLICATION DATE:	PERM	MIT ISSUED	NO.:	
	PLEASE PRINT A	LL INFORMATION		
I,	, do hereby apply for a permit for the following described			
work located at		Lot	Unit	
NOTE: Is proper		oric Preservation Di either yes or no	istrict? Yes No	
Subdivision	, Type of construction			
Description of proposed wor	k:			
Square feet in building	Estimated cost of construction			
Use of building	No. & Size of elect	No. & Size of electric meter No. & Size of water meters		
Remarks				
Plans			of Survey	
Owner of Property Name:		General Contract	or	
Address:		Address:		
City:		City:		
State/Zip Code:		State/Zip Code:		
Phone:		Phone:		
Electric Contractor Name:		Concrete Contractor Name:		
Address:		Address:		
City:		City:		
State/Zip Code:		State/Zip Code:		

Continued on reverse side

PLEASE PRINT ALL INFORMATION

Plumbing Contractors	Roofing Contractors			
Name:	Name:			
Address:	Address:			
City:	City:			
State/Zip Code:	State/Zip Code:			
Phone:	Phone:			
IL & Registration No.:	Illinois License No:			
	License Expiration Date:			
Sewer & Water Contractor	HVAC Contractor			
Name:	Name:			
Address:	Address:			
City:	City:			
State/Zip Code:	State/Zip Code:			
Phone:	Phone:			
plumbing, electric and other applicable ordinances of the cause all work to be performed according to the propersonally supervise the work and shall do, or causpecifications and other written information supplied a applicable ordinances and the provision thereof and responsible for all work accomplished under the permitshall call for inspections as required at a minimum of 24	ovisions of said ordinances. I, or my agent, shall use to have done, said work according to plans, as a part of this application. I am familiar with the d in signing this application do willingly become nit by all contractors, tradesmen and workmen, and			
PRINT NAME:S	IGNATURE:			
Name of actual business(s) that will occupy this space				
Remarks:	E 06" H			
	For Office Osc			
	Received			
Accepted: Rejected: Date:	Fee Paid \$			
Signed:	Receipt #			
Copies of application distributed to: Electric: Engineering:	Fire:			
Meter: PW:				
1 111	Historic Preservation:			